

ANNUAL WATER QUALITY REPORT

REPORTING YEAR 2018

Presented By
Town of Amherst



此報告包含有關您的飲用水的重要資訊。請人幫您翻譯出來，或請能看懂此報告的人將內容說給您聽。

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Our Mission Continues

We are once again pleased to present our annual water quality report covering all testing performed between January 1 and December 31, 2018. Over the years, we have dedicated ourselves to producing drinking water that meets all state and federal standards. We continually strive to adopt new methods for delivering the best-quality drinking water to you. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education, while continuing to serve the needs of all our water users.

Please remember that we are always available should you ever have any questions or concerns about your water.

The Benefits of Fluoridation

Fluoride is a naturally occurring element in many water supplies in trace amounts. In our system, the fluoride level is adjusted to an optimal level averaging 0.7 (ppm) to improve oral health in children. At this level, it is safe, odorless, colorless, and tasteless. Our water system has been providing this treatment since 1987. There are over 3.9 million people in 140 Massachusetts water systems and 184 million people in the U.S. who receive the health and economic benefits of fluoridation.



Information on the Internet

The U.S. EPA (<https://goo.gl/TFAMKc>) and the Centers for Disease Control and Prevention (www.cdc.gov) websites provide a substantial amount of information on many issues relating to water resources, water conservation, and public health. Also, the DEP has a website (<https://goo.gl/fg45jY>) that provides complete and current information on water issues in Massachusetts, including valuable information about our watershed.

Water Conservation Tips

You can play a role in conserving water and saving yourself money in the process by becoming conscious of the amount of water your household is using and by looking for ways to use less whenever you can. It is not hard to conserve water. Here are a few tips:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank. Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from an invisible toilet leak. Fix it and you can save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances. Then check the meter after 15 minutes. If it moved, you have a leak.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.



Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at (800) 426-4791 or at www.epa.gov/safewater/lead.



Substances That Could Be in Water

To ensure that tap water is safe to drink, the Department of Environmental Protection (DEP) and the U.S. Environmental Protection Agency (U.S. EPA) prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and which may also come from gas stations, urban storm-water runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

“ We remain vigilant in delivering the best-quality drinking water ”

Source Water Description

The Town currently has seven sources that contribute to meeting the water demand: Atkins Reservoir, the Pelham Reservoir System, the South Amherst Wells (#1 and #2), the Brown Well (#3), the Lawrence Swamp Well (#4), and the Bay Road Well (#5). Currently, the Atkins Reservoir and Well #4 are the primary water supplies, with Wells #1, #2, and #3 alternating as make-up water each day. These five sources supply approximately 90% of the total water produced. The Pelham Reservoir System and Well #5 operate during high-demand periods, or as needed, throughout the year.


In 2002, a Source Water Assessment Program (SWAP) was completed on the Amherst water system by the Massachusetts Department of Environmental Protection (MADEP). This SWAP report assesses the susceptibility of the town's drinking water sources to contaminants and outlines recommendations for drinking water protection. A copy is available at the Department of Public Works and online at <https://www.mass.gov/lists/source-water-assessment-and-protection-swap-program-documents#swap-reports-for-massachusetts-water-supplies>.



QUESTIONS?

For more information about this report, or for any questions relating to your drinking water, please call Guilford Mooring, Superintendent of Public Works, at (413) 259-3050.

IGNORE THE HYPE: DON'T FLUSH A WIPE!



BY THE NUMBERS

The number of Olympic-sized swimming pools it would take to fill up all of Earth's water.

800
TRILLION

1¢ The average cost for about 5 gallons of water supplied to a home in the U.S.

The amount of Earth's water that is salty or otherwise undrinkable, or locked away and unavailable in ice caps and glaciers.

99%

50
GALLONS The average daily number of gallons of total home water use for each person in the U.S.

Test Results

Our water is monitored for many different kinds of substances on a very strict sampling schedule. And, the water we deliver must meet specific health standards. Here, we only show those substances that were detected in our water (a complete list of all our analytical results is available upon request). Remember that detecting a substance does not mean the water is unsafe to drink; our goal is to keep all detects below their respective maximum allowed levels.

The State recommends monitoring for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

We participated in the 4th stage of the U.S. EPA's Unregulated Contaminant Monitoring Rule (UCMR4) program by performing additional tests on our drinking water. UCMR4 sampling benefits the environment and public health by providing the U.S. EPA with data on the occurrence of contaminants suspected to be in drinking water, in order to determine if U.S. EPA needs to introduce new regulatory standards to improve drinking water quality. Unregulated contaminant monitoring data are available to the public, so please feel free to contact us if you are interested in obtaining that information. If you would like more information on the U.S. EPA's Unregulated Contaminants Monitoring Rule, please call the Safe Drinking Water Hotline at (800) 426-4791.

REGULATED SUBSTANCES											
				Town of Amherst		Atkins Treatment Plant		Centennial Treatment Plant			
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	AMOUNT DETECTED	RANGE LOW-HIGH	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Alpha Emitters (pCi/L)	2017	15	0	0.555	ND–3.2	NA	NA	NA	NA	No	Erosion of natural deposits
Barium (ppm)	2018	2	2	NA	NA	0.0102	ND–0.0102	NA ¹	NA ¹	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Combined Chlorine (ppm)	2018	[4.0]	[4]	0.5	0.1–2.8	2.2	1.4–2.8	NA	NA	No	Water additive used to control microbes
Combined Radium (pCi/L)	2017	5	0	0.5	0.257–0.434	NA	NA	NA	NA	No	Erosion of natural deposits
Fluoride (ppm)	2018	4	4	0.7	0.20–0.80	0.7	0–1.1	NA	NA	No	Water additive which promotes strong teeth
Haloacetic Acids [HAA] (ppb)	2018	60	NA	16.3	ND–59.3	NA	NA	NA	NA	No	By-product of drinking water disinfection
Nitrate (ppm)	2018	10	10	1.20	0.281–2.27	ND	NA	NA	NA	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes] (ppb)	2018	80	NA	15.6	ND–54.0	NA	NA	NA	NA	No	By-product of drinking water disinfection
Turbidity (NTU)	2018	TT	NA	NA	NA	0.09	0.04–0.19	NA ²	NA ²	No	Soil runoff
Turbidity (Lowest monthly percent of samples meeting limit)	2018	TT = 95% of samples meet the limit	NA	NA	NA	100	NA	NA ²	NA ²	No	Soil runoff

Tap Water Samples Collected for Copper and Lead Analyses from Sample Sites throughout the Community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90TH %ILE)	SITES ABOVE AL/TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2017	1.3	1.3	0.100	0/31	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	2017	15	0	0.0054	0/31	No	Lead services lines, corrosion of household plumbing systems including fittings and fixtures; erosion of natural deposits

UNREGULATED SUBSTANCES (ATKINS TREATMENT PLANT)³

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Sodium ⁴ (ppm)	2018	8.78	ND-8.78	Erosion of natural deposits

UNREGULATED CONTAMINANT MONITORING RULE - PART 4

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH
HAA9 (ppb)	2018	23.7	ND-87
HAA6Br (ppb)	2018	1.2	ND-3.1
Manganese (ppb)	2018	0.003	ND-0.027

¹ Sampled in 2016.

² Sampled in 2017.

³ Unregulated contaminants are those for which the U.S. EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist U.S. EPA in determining their occurrence in drinking water and whether future regulation is warranted.

⁴ The Massachusetts Department of Environmental Protection maintains a guideline level of 20 ppm for sodium.

Definitions

90th %ile: Out of every 10 homes sampled, 9 were at or below this level. This number is compared to the Action Level to determine lead and copper compliance.

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

pCi/L (picocuries per liter): A measure of radioactivity.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.